



Project No. 608930

FP7-SMARTCITIES-2013

OPTimising Hybrid Energy grids for smart cities

**WP4 System Modelling and Simulation for the Evaluation of
the OrPHEuS Control Strategies**

Deliverable 4.3.2

**Technical evaluation of the OrPHEuS control strategies with
future business model**

D. Basciotti¹, S. Henein¹, H. Brunner¹, D. Stakic², K. Ditz²

¹AIT

²HSU

Version:	1.0
Due Date:	30 June 2016
Submission Date:	25 January 2017
Lead Coordinator:	¹ AIT

Copyright

@ Copyright 2013-2017 The OrPHEuS Consortium

Consisting of

Coordinator	WIP – Renewable Energies (WIP)	Germany
Participants	Hochschule Ulm (HSU)	Germany
	Stadtwerke Ulm GmbH (SWU)	Germany
	Technische Universität Wien (TUW-EEG)	Austria
	Austrian Institute of Technology (AIT)	Austria
	Deutsches Zentrum für Luft- und Raumfahrt EV (DLR)	Germany
	NEC Europe Ltd. (NEC)	UK
	Lulea Tekniska Universitet (LTU)	Sweden
	Skellefteå Kraft (SKR)	Sweden

This document may not be copied, reproduced, or modified in whole or in part for any purpose without written permission from the OrPHEuS Consortium. In addition to such written permission to copy, reproduce, or modify this document in whole or part, an acknowledgment of the authors of the document and all applicable portions of the copyright notice must be clearly referenced.

All rights reserved.

This document may change without notice.

Deliverable Description

Abstract: This deliverable provides the technical evaluation of the OrPHEuS control strategies co-simulation results enabling hybrid grid optimization using future business models, from the perspective of WP4. The deliverable first introduces an investigation methodology for a continuous enhancement of the control strategies developed in WP5, and then provides the technical indicators assessment for the two demo sites with different scenarios and variations: 1) removal of peak oil boiler usage and integration of waste heat from additional industrial customers for the district heating network of Skellefteå, Sweden and 2) storing and distributing heat produced with surplus photovoltaic power through the district heating network in Ulm, Germany. An additional scenario involving power-to-gas solution for the city of Ulm has been investigated only from the technical point of view, without the involvement of a dedicated control strategy from WP5. The final evaluation results contribute towards the holistic evaluation analysis task in WP7.

Key Words: smart cities, hybrid energy grid, co-simulation based evaluation, hybrid grid control strategy, smart grid, surplus photovoltaic power, E-rods, waste heat, power-to-gas, ICT

Document History

Version	Date	Authors	Description
0.1	14.10.2016	AIT	D4.3.2 Draft of deliverable outlining
0.6	18.01.2017	AIT	D4.3.2 Draft of deliverable without SKR2 results from electricity side
0.7	19.01.2017	NEC/HSU/WIP	Review of version 0.6
0.8	19.01.2017	AIT	D4.3.2 First Draft including all sections
0.9	24.01.2017	NEC/HSU/WIP	Review of version 0.8
1.0	25.01.2017	AIT	D4.3.2 Final version

Dissemination Level

Dissemination Level		
PU	Public	X
PP	Restricted to other program participants (including the Commission Services)	
RE	Restricted to a group specified by the Consortium (including the Commission Services)	
CO	Confidential, only for members of the consortium (including the Commission Services)	

Executive Summary

The OrPHEuS project explores hybrid energy network control system for smart cities implementing novel cooperative local grid and inter-grid control strategies for the optimal interactions between multiple energy grids. This is achieved by enabling simultaneous optimization for individual response requirements, energy efficiencies and energy savings as well as coupled operational, economic and social impacts. Starting from existing system setups in two cities, enhanced operational scenarios are demonstrated for today's market setup, as well as for future market visions. The deliverable supports the achievement of the STO3: Extended hybrid energy network modeling of cities' Hybrid Energy Networks, and of the objective results: Advances respecting different time horizons and time operational needs.

The main scope of the deliverable D4.3.2 (Task 4.3) is the technical evaluation and validation of the OrPHEuS collaborative control strategies for hybrid grids, developed in WP5, under **future business** models. The assessment and validation of the control strategies' simulation results is performed for the two demo sites, respectively Skellefteå (Sweden) and Ulm (Germany) for different scenarios and variations. The technical evaluation has been considered part of an iterative process for the definition/enhancement of the control strategies. The technical evaluation aimed at validating the scenarios' results from a technical operation point of view, in which operational limits, violations and/or possible technical impacts on the systems, according to the defined thermal and electrical KPIs in D4.2, have been investigated. It has also to be reported that deliverable D4.3.2 differs from deliverable D5.3.2 which evaluates the control strategies' performance, assessing achievements based on control strategy functionalities, targets and goals.

An additional scenario involving a power-to-gas solution for the city of Ulm has been investigated only from the technical point of view, without the involvement of a dedicated control strategy from WP5.

The technical evaluation of the different scenarios and variations contributes to the assessment of the control strategies' potential for the enhancement of hybrid grids. The evaluation methodology and the analysis of the simulation results for the single domains for both demo sites is described in Section 2. The evaluation of the control strategies for both demo sites from a hybrid grid prospective is reported in Section 3. The needed enhancement for the control strategies are coupled within the analysis of the results in an iterative process as feedback to WP5.

Administrative Overview

Task Description

Task 4.3: OrPHEuS control strategies evaluation in simulation environment

Input from: Task 5.3, Task 2.3, WP3

The control strategies developed in WP5 task 5.3 are modelled and integrated in the simulation and evaluation environment of Task 4.3. The different load and generation models from Task 4.1 and 4.2, including historical data from the demo sites (WP3), deliver the input parameter for the model-based predictive OrPHEuS control strategies.

The analysis of the capability of the control strategies to overcome possible technical constraints is done in task 4.3, taking into consideration the interaction of the different energy carriers based on different use cases and scenarios developed in cooperation with WP2 (thermal-electrical coupling), which will be evaluated in a second step.

The simulations give input for requirements of the monitoring system in WP3. Additionally the evaluation of the necessary data flows to run the control strategies gives input for ICT requirement and gap analysis of the demo sites in WP3. An iterative enhancement of the OrPHEuS control strategies will be done in WP5 according to the analysis of the simulation results.

Relation to the Scientific and Technological Objectives

This deliverable is related to the achievement of the STO3 – “Extended hybrid energy network modeling of cities’ Hybrid Energy Networks” and of the objective / expected results: “Advances respecting different time horizons and time operational needs”.

It is related to the Performance Indicator:

No.	Objective/expected result	Indicator name	STO	Deliverable	MS	Expected Progress		
						Year 1	Year 2	Year 3
15	Validation of the control strategies in the Simulation Environment	Simulation environment	STO3	D4.3.2	MS3			Due: M30 Draft: M27

Relations to activities in the Project

Relationship to previous and future tasks in the WP

- Inputs:
 - WP2 Task 2.3: different use cases and scenarios
 - WP3: historical data from the demo sites
 - WP5 Task 5.3: cooperative control strategies for both demo sites using current business model
- Outputs:
 - WP2: provides simulation evaluation results for evaluation/validation

- WP3: requirements of the monitoring system, ICT requirements and gap analysis of demo sites
- WP5: further improvement and enhancement of the control strategies
- WP7: control strategies technical evaluation results as an holistic analysis for the final recommendations

Terminologies

Definitions and abbreviations

The definitions and abbreviations are reported directly in the text.

Table of Contents

1	Introduction.....	8
1.1	Scope of the document	8
1.2	Structure of the document.....	8
2	Single domains: technical evaluation of the control strategies	9
2.1	Methodology	9
2.2	Skellefteå demo site	10
2.2.1	Introduction.....	10
2.2.2	Thermal domain	10
2.2.3	Electricity domain.....	16
2.3	Ulm demo site	21
2.3.1	Introduction.....	21
2.3.2	Electricity domain.....	21
2.3.3	Thermal domain	28
2.3.4	Ulm2: Power to gas scenario.....	32
3	Hybrid grid technical evaluation of the control strategies.....	36
3.1	Skelleftea demo site	36
3.2	Ulm demo site	36
	Annex 1: Skelleftea Thermal Side.....	38
	Annex 2: Skelleftea Electrical Side.....	41
	Annex 3: Ulm Thermal Side	46
	Annex 4: Ulm Electrical Side	47
	Annex 5: Ulm Power to Gas scenario	49
	References.....	54
	Disclaimer	55
	Contacts.....	56

1 Introduction

1.1 Scope of the document

The scope of this document is to support the overall aim of OrPHEuS on the development of collaborative hybrid grid control strategies on a simulation basis, by applying new control strategies in an enhanced multi-domain simulation environment (focusing on electricity and district heating domains). In the document, under the future business model boundary conditions, different variations for the demo site Skellefteå (Sweden) and Ulm (Germany) have been investigated and with the help of the technical indicators defined in the deliverable D4.2 the related control concepts have been evaluated. The detailed description of control strategy algorithms, scenarios and variations is provided in the deliverable D5.3.2. Additionally it has to be reported that deliverable D4.3.2 does provide only the technical evaluation of results (operational limits violations and/or possible technical impacts on the system) and differs from deliverable D5.3.2 in which the evaluation of the control strategies performances is reported, e.g. including achievements based on control strategies' functionalities, targets and goals.

The document includes additionally the power-to-gas scenario involving power-to-gas solutions for the city of Ulm, investigated only from the technical point of view, without the involvement of a dedicated control strategy from WP5.

This deliverable is related to the achievement of the STO3 – “Extended hybrid energy network modeling of cities’ Hybrid Energy Networks” and of the Objective / Expected result: - “Advances respecting different time horizons and time operational needs”.

1.2 Structure of the document

This document is structured as follows:

Chapter 2 presents a **general description of the methodology** used to evaluate and enhance the proposed control strategies from WP5 in both demo sites from the point of view of the electric and the thermal grid systems. Additionally it describes the effects of the control strategies for the two demo sites while analysing the technical KPIs under different boundary conditions. Furthermore, it introduces a possible alternative with power to gas and the analysis of the results done by project partner HSU.

Chapter 3 introduces and **evaluates control strategies from the hybrid aspects** point of view, for the demo sites of Skellefteå (Sweden) and Ulm (Germany). This chapter presents the analysis of the interconnections between technical KPIs from both domains, respectively the electrical and thermal networks.

2 Single domains: technical evaluation of the control strategies

2.1 Methodology

The simulation set-up developed in Task 4.1 and described in the deliverable D4.1 serves as a real-life simulation-based testing lab for the OrPHEuS project and key performance indicators, defined in the deliverable D4.2, are used to test and compare the various scenarios and variations developed within WP5 and described in the deliverable D5.3.2. In this section the technical indicators from the D4.2 process are used for the evaluation of the simulation runs in order to assess the influence of the control strategies on the specific domains (electricity and thermal). The mutual interdependencies between the thermal and electricity domains are analyzed separately in Section 4. As a result from the evaluation of the single domains as well as from the hybrid grids point of view, enhancements have been provided to the control strategy concepts of WP5 as well as to the monitoring concepts of WP3. The details of the single domains control strategy evaluation are reported for the Skellefteå demo site in Section 2.2. The details of the single domains control strategy evaluation are reported for the Ulm demo site in the Section 2.3.

Moreover it has to be stated that the evaluation process has been serving the enhancement and improvement of both thermal and electrical models and control strategies development. This evaluation process takes into account not only technical operation limitations and technical KPIs for both electricity and thermal domains but also the possible application of these strategies using the capabilities of the existing and new devices. The continuous enhancement includes the added elements' design, their operation limitations and also the operation conditions and limits of both domains. Meanwhile the scenarios correspond to different seasons to reflect the real possible thermal and electrical consumption and production.

In order to investigate the sensitivity of control strategies to boundary condition variations (e.g. electricity demand increase, thermal demand increase, etc.) the OrPHEuS consortium agreed on testing a number of variations as described in detail in D5.3.2.

For the Skellefteå demo site as reported in the Sections 2.2.2 and 2.2.3, the evaluation of the simulation results has been performed for two different electricity tax conditions, since it is expected in the future that they will be significantly decreased from the current value, allowing power-to-heat solutions to enhance energy grid performances. Additionally, variations including different electric boiler sizes, electric battery capacities, different industrial load demands and heating demand conditions have been investigated. The simulations are visualized, when required, in a matrix scheme as showed for example in Figure 3.

For the Ulm demo site as reported in Sections 2.3.2 and 2.3.3 evaluation of the simulation results has been separately performed for the 2 main control strategies using one central electric boiler and one heat storage. As for the Skellefteå demo site, also for the Ulm2 scenario different system setting variations (limitations of heat overproduction export to Eisingen) as well as two PV penetration variations have been investigated.

A detailed description of the control strategies as well as parametric variation is reported in the deliverable D5.3.2.

2.2 Skellefteå demo site

2.2.1 Introduction

The evaluation of the KPIs from the simulation results for the Skellefteå demo site has been divided into the thermal and electricity domains and is reported respectively in the Sections 2.2.2 and 2.2.3. A short summary of the parametric variations is reported in the following paragraph.

- **Size of the electric battery (4)** – 0MW/0MWh, 1MW/1MWh, 5/5MWh, 10MW/10MWh (peak load/capacity): on the basis of the analysis of the performance data of the electricity grid and the preliminary economic evaluation from WP3, WP4 recommended the investigation to start with these four sizes.
- **Additional industrial customer electric load (4)** – 10-20-30-40 MW: WP3 recommended the investigation to start with these four sizes.
- **Heat demand conditions (4)** – 0-5-10-20%: increase of the demand as compared to the typical winter conditions defined in D4.3.1. Four demand conditions have been chosen and the co-simulation investigations are limited to the winter season, which is defined as November to March. The 5 months were set by selecting the months most likely to require peak heating.
- **Control strategies (2)** – baseline and “Control-R” (detailed description provided in D5.3.2): From the requirements of the stakeholders, WP5 set two practical control goals. One is the baseline (extension of the concept for the baseline defined in D5.3.1) for which the assumption that oil is not used anymore for heating is considered; “Control-R” considers to optimize the operation of the DH and electricity systems from a cost point of view (including CO₂ taxes and all operational costs).
- **Electricity tax conditions (2)**: Two electricity tax conditions: respectively 0.5 €/MWh (based on possible future regulations to support electricity usage) and 19.5 €/MWh (as today conditions) on top of the electricity price.

In total, the simulation-based investigation delivered 64 baseline variations and 64 Control-R variations (as combinations of the abovementioned parameters). The evaluation of the simulation runs for the Skellefteå demo site in the case of the Scenario 1 is reported in the Sections 2.2.2 and 2.2.3 respectively for the thermal domain and the electricity domain.

A detailed description of the control strategies as well as parametric variation is reported in the deliverable D5.3.2.

2.2.2 Thermal domain

The analysis of the simulation runs under different boundary conditions (e.g. size of the electric battery, size of the additional industrial customer, etc.) is performed also considering the KPIs defined in the deliverable D4.2. The results, as shown for example in Figure 3, are visualized in a matrix approach by dividing them into 8 groups for which the columns are the size of the industrial customer (10 MW, 20 MW, 30 MW, 40 MW), and rows are the electricity tax conditions (0,5 €/MWh and 19.5 €/MWh). Results are presented by comparing the baseline with the alternative control strategy.

As explained in deliverable D5.3.2 in the description section of the Ulm Future Scenario, the baseline assumes no heat pump for the usage of waste heat from the industrial customer.

Figure 1 and Figure 2 show two single representative days in order to evaluate the effects of the control strategy on the heat production distribution (scenario with an electric boiler of 100 MW, electricity tax condition of 19.5 €/MWh, battery size 10MW/10MWh, additional industrial customer of 40MW, additional heating load of 20% and control R setup). On the representative day in January, see Figure 1, the target (from the district heating point of view reducing operational costs) is achieved by charging overnight the storage tank (and partly using heat from it) and during the day discharging the storage tank (until around 18:00) and using the biomass boiler, the CHP and the heat pump.




Figure 1: SKR2, Heat load distribution (representative day in January with control R)

On the representative day in March, see Figure 2, the target of reducing operational costs is achieved by using the CHP, the heat pump and the electric boiler. The storage tank buffers only heat produced from the electric boiler in the timeframe between 9:00 and 15:00. The biomass boiler is not operated for long periods (on the representative day in March for one full day).




Figure 2: SKR2, Heat load distribution (representative day in March with control R)

Figure 3 visualizes heat production distribution in a matrix approach for which the columns are the size of the industrial customer variations (10 MW, 20 MW, 30 MW, 40 MW), and rows are the electricity tax condition variations (0.5 €/MWh and 19.5 €/MWh). From the analysis of the results, it can be stated that there is no effect of the electricity tax conditions on the decisions of the operation conditions, meaning the heat production distribution is similar with low and high electricity taxes.

Large variation in heat production from heat pump (using the waste heat from the additional industrial customer) and e-boiler occurs when varying the additional industrial customer electricity demand (available waste heat is coupled to the electricity demand of the industrial customer). The heat pump operation hours is for the industrial customer of 10 MW about 2900h, while for the case of an industrial customer of 40 MW is about 2100h with a reduction of about 800h. The heating demand increase (variations with 0, 5, 10 and 20%) shows a difference in the usage of both electric boiler and heat pump with a difference between 0 and 20% of 17% more usage of heat pump and 45% more electric boiler and no difference with different sizes of electric boilers.

Figure 4 visualizes heat distribution losses for the district heating network in a matrix approach for which the columns are the size of the industrial customer variations (10 MW, 20 MW, 30 MW, 40 MW), and rows are the electricity tax condition variations (0.5 €/MWh and 19.5 €/MWh). From the analysis of the results, it can be stated that there is no effect of the electricity tax conditions on the decisions of the operation conditions, meaning the heat distribution losses is similar with low and high electricity taxes. Moreover the control strategy and the electric battery variations don't influence the heat distribution losses (no effect on the supply and return network temperatures). Heating demand variations have an effect with is a minimum value of heat distribution losses of 12300 MWh for the 0% heat demand increase scenario and 14800 MWh for the 20% heating demand increase scenario.




Figure 3: SKR2, Energy heat production distribution split in industrial customer variations (rows) and electricity tax conditions (columns)




Figure 4: SKR2, Heat losses split in industrial customer variations (rows) and electricity tax conditions (columns)

Figure 5 shows storage temperature average results for the industrial customer of 10MW. No large differences are occurring for other sizes of industrial customer (20 MW, 30MW and 40MW) and for different size of electric battery and therefore they are not represented in Figure 5. The tabular form of the complete dataset is reported in the Annex I. Moreover from the analysis of the results it can be stated that the control strategy reduces the usage of the storage tank with lower average storage temperatures compared to the baseline for all variations (decrease from 85°C to about 73°C for the case of heating demand increase of 20% by using directly more the heat pump).




Figure 5: SKR2, average temperature levels of the top layer for the electricity tax condition 0.5€/MWh (top) and 19.5 €/MWh (bottom)

2.2.3 Electricity domain

The analysis of the simulation runs under different boundary conditions (e.g. size of the electric battery, size of the additional industrial customer, etc.) is performed also considering the KPIs defined in the deliverable D4.2. The results, as shown for example in Figure 6, are visualized in a matrix approach by dividing them into 4 groups for which the columns are the size of the industrial customer (10 MW, 20 MW, 30 MW, 40 MW), and rows are the electricity technical KPI's (network losses, maximum voltage spread, etc.). Comparison are done for different scenarios and variations such as electricity tax conditions (epr1 corresponding to 0.5 €/MWh and epr2 corresponding to 19.5 €/MWh), different heat demand increase from 0% to 20% (named hd0, hd5, hd10, and hd20) and different electric storage sizes (Eb1, Eb5, and Eb10), see Section 2.2.1. The developed control strategies results are compared with the baseline. As explained in deliverable D5.3.2 in the description section of the Ulm Future Scenario, the baseline assumes no heat pump for the usage of waste heat from the industrial customer.

Figure 6 shows a comparison of network losses of all scenario variations and control strategies, which demonstrates a reduction of about 14% in network losses for no heat demand increase scenario with epr2 (electricity price 19.5 Euro/MWh) and Eb1 (electric storage size 1 MW) (electrical industrial customer electricity load 10 MW). The same variation shows a voltage spread reduction of about 5%. The voltage spread reduction of the other different scenarios is between 16% and 42%, reflecting under voltage violations problems.




Figure 6: SKR2: network losses and maximum voltage spread of different scenarios and variations

The different variations of the scenarios, Industrial load 20 MW, Industrial load 30 MW and Industrial load 40 MW, show an increase in network losses between 28% and 34%.

Figure 7 presents the maximum transformer loading of transformer 1 which is reduced by 51.76% and 11.3% for scenario eprice1, no heat demand increase, and battery size 1 for both Industry 10 MW and Industry 20MW variations. On the contrary for both variations Industry 30 MW and Industry 40 MW, all different scenarios and variations show a transformer 1 loading increase. Additionally Figure 7 shows the duration of the transformer 1 overloading over 80% for 99% of the simulation time.




Figure 7: maximum first transformer loading and its duration of different scenarios and variations

Figure 8 shows that, there is transformer loading reduction of transformer 2 with respectively 33.3%, 10%, 31.3%, and 30% for the variations Industry 10 MW, Industry 20 MW, Industry 30 MW and Industry 40 MW for scenario eprice1, no heat demand increase, and electric battery size one. Additionally, Figure 8 shows the duration of the transformer 1 overloading over 80% which accounts for only 1% of the simulation time. Although in most scenarios and variations there is transformer loading reduction, still the values of the loading of both transformer are very high and are not within the acceptable operational limits.




Figure 8: maximum second transformer loading and its duration of different scenarios and variations

Figure 9 presents the maximum line loadings and the duration of the overloading of lines over 80%. It shows very high lines overloading between 160% and 315% which cannot be accepted even when the duration of some of these violations is short. These violations accounts for around 40% of the simulation period.




Figure 9: maximum line loadings and their durations of different scenarios and variations

As a conclusion from all results shown in this section there is an improvement of the different KPIs, especially for the scenario with low electricity tax conditions, no heat demand increase and electric storage size of 1 MW for different electricity industrial load consumptions. Nevertheless, both transformers and lines experience large violations of the network limits (loading exceeds 80% for long durations).

2.3 Ulm demo site

2.3.1 Introduction

For the Ulm demo site, two control strategies with one central electric boiler and heat storage have been evaluated: one is maximizing heat export, which targets to directly export the heat generated from PV surplus and the other is keeping the storage charged, which is targeted on keeping heat in the storage for local usage rather than exporting it.

As explained in deliverable D5.3.2 in the description section of the Ulm Future Scenario, the baseline assumes no storage tank installed and no usage of e-rods in Eisingen. The overall heat production comes from the 3.0 km long pipeline connected to the wider DH system of Ulm. Therefore all values were compared to the baseline values in order to evaluate the impact of different scenarios on the network KPIs and operation limits. The evaluation of the KPIs from the simulation results for the Ulm demo site has been divided into the electricity and thermal domains and is reported respectively in Sections 2.3.2 and 2.3.3.

For the two control strategies, a short summary of the parametric variations is reported in the following paragraph. For both control strategies, limitation of heat overproduction in Eisingen has been chosen and control goals have been analyzed.

- **PV penetration rate** – PV50% and PV75%: the penetration share describes the number of buildings on which PV plants are installed (e.g. 50% means that 50% of the buildings have a rooftop PV plant). Two possible penetration shares are suggested as the possible future by HSU and SWU.
- **Limitation of heat overproduction in Eisingen** – 0 kW - 100 kW – 200 kW - 300 kW - 400 kW – 500 kW - unlimited: on the basis of the limitations of thermal energy export to the heating network of Ulm, and therefore the amount of discharging is still limited by the sum of the local heat demand of Eisingen and the maximum heat export value of the particular scenario under consideration, these overheat production limitations are recommended to be investigated. No electric boiler usage is considered for the baseline.
- **Control strategies**– Baseline, Control A, and Control B: detailed description of the control strategies included in deliverable D5.3.2

The evaluation of the simulation runs for the Ulm demo site in the case of the Scenario 2 is reported in the Section 2.3.2 and 2.3.3 respectively for the electricity and thermal domain.

A detailed description of the control strategies as well as parametric variations is reported in the deliverable D5.3.2.

2.3.2 Electricity domain

The analysis of the simulation runs under different boundary conditions (e.g. PV penetration share, limitation of heat overproduction to Ulm as well as the two control strategies) is performed by assessing the KPIs defined in the deliverable D4.2. The results are visualized in a matrix approach by dividing them into 6 groups for which columns are the control strategies (A and B), and rows are the KPIs (total network losses, maximum voltage spread and duration transformer loading). The results are presented by comparing the baseline with the alternatives. The two PV penetrations levels are

analysed separately and presented in Sections 2.3.2.1 and 2.3.2.2. The complete dataset of the results for the Ulm scenario is reported in Annex 4.

2.3.2.1 PV 50% scenario

Figure 10 shows a comparison of the different technical KPIs defined for electricity grid comparing the baseline with different heat transport limitation variations for control strategies A and B. In the same time these reflect the effect of these variations on the electricity network KPIs.




Figure 10: total network losses and maximum transformer loading

As shown in Figure 10, there is a reduction of the total network losses of about 17.3% in the case of control A with unlimited heat overproduction in Einsingen. Similar results for transformer loading can be seen in Figure 10, as control strategy A with unlimited limitation of heat overproduction shows the maximum reduction of the maximum transformer loading, compared to other scenarios, about 10.2%.




Figure 11: maximum line loading and maximum voltage spread

The same scenario shows a decrease of the maximum voltage spread of about 10.2% (Figure 11). With a total maximum voltage spread of 95%, this is within the limit. The results in Figure 11 shows

that there is no improvement in the line loadings as it increases in a range from 0.5% – 1.0% compared to the baseline scenario. The duration of maximum line overloading over 80% is about 10% of the whole simulation time. Control A reflects better results than Control B from the technical operational point of view. Control A variations show improvement in total network losses, transformer loading, and voltage band usage. From the total results shown in Figure 10 and Figure 11, the control A strategy with unlimited heat overproduction in Einsingen, shows the best results and can be considered as the best solution from the introduced variations.

2.3.2.2 PV 75% scenario

Figure 12 shows a comparison of the different technical KPIs defined for the electricity grid comparing the baseline with different heat transport limitation variations for control strategies A and B. In the same time these reflect the effect of these variations on the electricity network KPIs.




Figure 12: total network losses and maximum transformer loading

It shows similar results to the 50% PV penetration variation, as the total network losses decrease with about 19% in the case of control A with unlimited limitation of heat overproduction in Einsingen compared to the baseline scenario.

Similar results for transformer loading can be seen in Figure 12, as control strategy A with unlimited limitation of heat overproduction shows the maximum reduction of the maximum transformer loading, compared to other scenarios, of about 33.4%.




Figure 13: maximum line loading and maximum voltage spread

The same scenario shows a decrease of the maximum voltage spread of about 6.5% (Figure 13). With a total maximum voltage spread of 133.4%, this is not within the limit. As the results in Figure 13 shows that there is no improvement in the line loadings as it increases in a range from 0.4% – 0.7%

compared to the baseline scenario. The duration of maximum line overloading over 80% is about 16% of the whole simulation time.

Considering the evaluation of performance results in D5.3.2, it can be stated that analysing the technical indicators of the control strategies Control A performs better than Control B from the technical operational point of view. Control A variations show improvement in total network losses, transformer loading, and voltage band usage. From the total results shown in Figure 12 and Figure 13, the control A strategy with unlimited heat overproduction in Einsingen, shows the best results and can be considered as the best solution from the introduced variations.

2.3.3 Thermal domain

The analysis of the simulation runs under different boundary conditions (e.g. PV penetration share, limitation of heat overproduction to Ulm as well as different control strategies) is performed also considering the KPIs defined in the deliverable D4.2. The results, as showed for example in the Figure 17, are visualized in a matrix approach by dividing them into 3 groups for which the columns are the control strategies (A and B), and rows are the PV penetration shares (50% and 75%). Results are presented by comparing the baseline with the alternative. The complete dataset of the results for the Ulm scenario is reported in the Annex 3.

As explained in deliverable D5.3.2 in the description section of the Ulm Future Scenario, the baseline assumes no storage tank installed and no usage of e-rods in Eisingen. The overall heat production comes from the 3.0 km long pipeline connected to the wider DH system of Ulm. Therefore in the baseline both energy productions from e-rod and energy demand from the wider city of Ulm is respectively 0 MWh.

From Figure 14 to Figure 16 three single representative days are displayed in order to evaluate the effects of the control strategies on the heat production distribution (control A in the specific examples). In the case of control A, the target is to directly export the heat generated from PV surplus, by keeping discharging the storages as much as possible. Whenever there is PV generation surplus, the heating power of the e-boiler is set to exactly that surplus as long as the heat storage is not full, which, due to the aggressive heat export policy, is expected to happen only rarely. As shown in Figure 14, as soon as the storage temperature, due to charging from the e-rod, reaches the required supply temperature of the network the storage is discharged. Considering a small surplus in January from PV, the discharging of the storage is limited to daytime periods between 12:00 and 15:00.




Figure 14: Ulm2, Heat load distribution (representative day in January with control A)

Considering the lower requirements in transitional period (April) and summer (July), Figure 15 and Figure 16 show an increasing discharging time period, which in the case of July is between 08:00 and 19:00, corresponding to the PV generation time period.




Figure 15: Ulm2, Heat load distribution (representative day in April with control A)




Figure 16: Ulm2, Heat load distribution (representative day in July with control A)

Figure 17 shows in blue bars: 1) the heat demand from Eisingen, 2) the exported heat (consumption) to Ulm and 3) the heat losses from the pipelines (including the connection to Ulm); and in red bars: 1) heat production coming from Ulm and 2) heat production from the e-rod.

Considering PV penetration 75% in the case of heat export limitation of 300 kW it shows that 1397 MWh is produced from the e-rod, covering totally the heat distribution losses and heat exported to the wider district heating grid of Ulm. In the case of PV penetration of 50% the effect of the heat export limitations show that in the case of unlimited export a maximum of 1692 MWh per year can be produced covering totally heat distribution losses but only partly the heat demand from Ulm.

In case of Control B the control strategy avoids exporting the heat to the city of Ulm (except when the storage is about to get full) and uses the surplus PV as heat production for the Eisingen demand. In this case having as target the Eisingen demand as priority, the limitation of Ulm are less influencing than in the control A. E-rod energy production for the different variations of heat export limitations is between 896 MWh and 1197 MWh. Small differences are assessed between PV50% and PV75%, considering the heat demand from Eisingen the limiting factor for e-rod energy production.




Figure 17: Ulm2, energy demand and production for different heat export limitations

Figure 18 shows the top layer temperatures from the highest to the lowest value for different heat export limitations split into different PV penetration and control strategies. Following the control logic of control B, the storage top temperature is not affected by the heat export limitations across all variations (see also Figure 19 for average values). The resulting decreasing storage top layer temperature follows the set point of the network supply temperature (linear function of outdoor temperature with 90°C at -10°C and 75°C at $+15^{\circ}\text{C}$). In case of control A, the larger the amount of heat that can be exported to the city of Ulm, the lower the heat stored in the storage tank, assuming that the control logic simultaneously releases the heat from the storage tank when available (see also Figure 19 for average values).




Figure 18: Ulm2, temperature levels of the top layer ordered from the highest to the lowest value for different heat export limitations




Figure 19: Ulm2, average temperature levels of the top layer ordered from the highest to the lowest value for different heat export limitations

2.3.4 Ulm2: Power to gas scenario

2.3.4.1 Motivation

Within the framework of the OrPHEuS project, this scenario did not require any control strategy development. A separate approach, from a feasibility study point of view, has been performed by HSU and it is reported in the following sections. The details of the methodology (modelling approach) used for the power-to-gas scenario are reported in Annex 5.

Power to gas represents an alternative solution, which has been requested by the network operator SWU to be analyzed, and recently is attracting more interest from the research and development point of view. Power to gas (PtG) systems could be a solution to minimize electric surplus problems. They are an opportunity for peak shaving measures and for seasonal storage. Power-to-gas systems are not state-of-the-art but actual R&D topics with some single demonstration projects around the world (with deliverable D3.2 showing an overview of the current PtG projects in Germany).

In principle, when more energy (e.g. from solar panels) is produced than consumed, the power can be used to split water it into hydrogen and oxygen by using electrolysis or hydrolysis. Further existing possibilities are:

- Up to 5% of hydrogen can be directly stored in the gas grid [8].
- The hydrogen can be stored in tanks and used in other applications
- With the methanation process, the hydrogen can be transformed into methane. This can be realized with the Sabatier process or in a bio-reactor by using specific bacteria [9]

The advantage of methanation is the available gas grid, which represents a big storage. It is possible to use the produced gas for heat supply or it can be converted back to electricity if needed. The actual problem concerning this process is the low efficiency. In combination with waste heat recovery processes efficiencies up to 85% are possible [8].

2.3.4.2 Scenario description

It has to be highlighted that PtG systems also do not avoid completely voltage band violations or overloaded lines due to the fact that those systems are connected to a single connection point of the electric grid. From that point of view decentral electric power loads is the only option able to completely avoid grid reinforcement [3].

The hybrid scenario extends the domestic hot water (DHW) and space heating (SH) discussed in D4.3.1 by using a PtG as coupling point to the gas grid. The output data (transformer load) from the co-simulation of ULM1 SH and DHW scenario is used as input for the PtG scenario. The analysis involved the scenario under PV-potential 50 % and 75 %. In Eisingen is the PtG scenario set on top of scenario 1.2 were decentral PtH for SH and DHW is involved. For Hittistetten the whole PV-surplus is used for the hydrogen production. However in Hittistetten no co-simulation has been considered.

2.3.4.3 Baseline Results

To evaluate the baseline in case of the gas grid and the correlation of the energy flows in the hybrid system, the heat demand and the PV surplus in the test area Eisingen is balanced and cumulated as shown in Figure 20. For this analysis only power and energy flows from the total test area Eisingen are used and neither grid, nor storage nor control strategies were implemented.




Figure 20 Cumulated daily energy demand of the electrical PV surplus and the total heat demand over on year test side Einsingen.

The PtG approach can only balance the PV surplus with the gas consumption. The gas demand is only part of the total heat demand and is therefore lower. The lower efficiency of the power to gas process ($\eta(\text{H}_2) \approx 0,75$ and $\eta(\text{CH}_4) \approx 0,5$) does not totally negates the effect on the seasonal PV surplus.

Figure 21 shows the total load flow of the gas in nominal cubic meters for the two test areas. It shows the strong difference of the gas consumption between summer and winter and the temperature dependency. Gas grid areas with more industrial and business companies have also in summer time a higher gas consumption for their production processes. These will result in a positive effect for PtG because more power can directly consumed and does not have to be stored or transported over long distances. The values in Figure 21 were simulated with the gas grid model described in Annex 5.




Figure 21 Total gas load flow at Einsingen (top) and Hittistetten (bottom) for the baseline

Table 1 gives an overview of the resulting PV surplus energy for three PV future scenarios in Einsingen. These scenarios are defined for the co-simulation in Einsingen. The additional hydrogen percentage is limited due to technical and legal (max. 5 %) specifications. This has a strong influence to the available feed-in capacity of the gas grid for hydrogen. The yearly seasonal PV surplus from summer into winter time could cover from 7 % to 23 % of the annual heat demand depending on the different PV potential scenarios. Without the seasonal PV surplus the usage could be from 6 % to 16 %. If a seasonal PV surplus is considered the usage rate increases by 7 % of the heat demand in the 100%-PV potential scenario.

Table 1: seasonal PV surplus for local PtG (H₂) and (CH₄) in Einsingen

	PtG (H ₂)	PtG (CH ₄)
100%-PV Surplus [MWh]	213.73	96.02
75%-PV Surplus [MWh]	126.87	43.87
50%-PV Surplus [MWh]	11.31	0

With the geometrical and topological information of the gas grid infrastructure the grid volume and the energy storage capacity can be calculated. The medium pressure (MP) grid is supplying a bigger area (Figure 24 in Annex 5) than the in OrPHEuS defined test area Einsingen. The downscaling of the storage capacity from the MP grid area to the test area is based on a calculation of a factor based on the inhabitation in the region and the test area. The MP gas grid in the test area Einsingen provides a storage capacity of 207.1 kWh for methane (100 % potential) and 3.11 kWh (5 % potential) for hydrogen, respectively. Suburban MP gas grids, as e.g. in the test area Einsingen, cannot deliver the

seasonal storage capacity which is necessary if the seasonal PV surplus will increase to a high level of usage of roof potential for PV. Most urban areas include a high pressure (HP) distribution gas grid and can use this in combination with the PtG technology as a seasonal storage. A first estimation of the HP gas grid of the city of Ulm results in a storage capacity of 600 MWh. Combined with an average base load of 106.45 MW for summer time (June, July, August) results a high power shifting potential. The capacity in Ulm is strongly influenced by a pipe storage and is therefore not typical for most European cities. This pipe storage is fed from the transmission grid and has about the same volume as the total distribution HP gas grid of the city. However, it is operated on a higher pressure level and these results in a higher energy storage capacity. The HP distribution gas grid without the pipe storage in Ulm has an estimated storage capacity of 84 MWh (0.7 kWh per inhabitant of Ulm). [3]

2.3.4.4 Power to gas scenario results

The results from the grid models and approach of the controller and planning parameters of the electrolyser and methanation are described in Annex 5. These efforts deliver a more precise analysis than the calculation in the baseline analysis in Section 2.3.4.3. The daily average load flow at the transformer for the year 2014 in Hittistetten and Eisingen has been analysed. Figure 22 shows the analysis with PV50% and PV75% potential with and without electrolyzer for both Eisingen and Hittistetten. Negative values mean load flow without electrolyzer shows that on average for those hours of the day the total PV-production is higher than the demand over the year. For Eisingen (left), based on the results of Ulm SH and DHW with control strategy 2, a large amount of PV-surplus has already been used by the developed power-to-heat solution. For Hittistetten no power-to-heat has been developed therefore there are higher negative values in the case without electrolyzer. In both cases, the maximum power at the transformer will be strongly reduced, resulting in complete consumption of the PV Energy; see Figure 22. This reduces also the stress for all higher voltage grid levels and gains direct positive effect for the voltage, frequent and power regulation at the medium voltage grid to the city.




Figure 22: Daily averaged yearly loadflow with and without electrolyzer for Eisingen (left) and Hittistetten (right)

3 Hybrid grid technical evaluation of the control strategies

The following sections describe the evaluation from a combined thermal and electricity domain point of view for the Skellefteå and Ulm demo sites in Scenario 2 (future business model). “Best” configurations and effects of the boundary conditions for the control strategies performances are summarized and highlighted.

3.1 Skelleftea demo site

The Skellefteå future scenario analysed in this deliverable can be considered as “thermal-domain” driven, due to its nature. Indeed the aim of the scenario is the removal of peak oil boiler usage (zero CO₂ emissions targets) and waste heat usage from an additional industrial customer with high electricity demand. The high electricity demand has the implication on the electricity grid to stress it and therefore, both from an economic perspective and energy efficient perspective, hybrid grid solutions investigation assessed possible synergies. The coupling points between the two grids are represented by the heat pump and the electric boiler, the first enabling the conversion of low grade waste heat.

According to the evaluation of the results for the electric domain there is an improvement of the KPI's especially for the scenario with low electricity tax conditions, no heat demand increase and an electric storage of 1MW for the different industrial electricity load scenarios. Nevertheless transformer and line loading violations, outside the allowed/accepted limit, are occurring. This scenario therefore requires that, from a technical point of view, the maximum electric boiler size of 35 MW is considered or that decentralised small electric boilers are installed.

For the district heating network, the control strategy enables the efficient usage of low grade waste heat from the industrial customer, with heat pump operation of about 2900 hours per year in the case of an industrial customer of 10 MW and 2100h when the industrial customer electricity demand increases to 40 MW. Under future heating demand increase perspectives, the controller supports an additional increase of heat pump and electric boiler heat production respectively of 17% and 45% compared to the status quo heating demand of the grid. From the analysis of the technical indicators, the control strategy shows limited effects on the operation of the storage tank (reduced usage) and heat distribution losses (limited influence on the supply network temperature).

3.2 Ulm demo site

The Ulm future scenario analysed in this deliverable aims at increasing local consumption of electricity surplus generated by the PV plants, where a central electric boiler and heat storage are used as coupling points transferring energy from the electricity grid to the heating grid, in order to avoid transformer overloadings and electricity flow backs to the grid.

According to the evaluation of the results for the electric domain, Control A variations show improvement in total network losses, transformer loading and voltage band usage. From the total results shown in Figure 10, Figure 11, Figure 12 and Figure 13 the control A strategy with unlimited limitation of heat overproduction in Eisingen, outstands among the different variations, due to its contribution to minimize network losses, transformer loadings, as well as voltage band usage. There is a reduction of the total network losses of about 17.3% and 19% in the case of control A with unlimited limitation of heat overproduction in Eisingen, which reflects the reduction of the flow

back to the medium voltage through the share of the PV systems. Similar results for transformer loading can be seen in Figure 10 and Figure 12, as control strategy A with unlimited limitation of heat overproduction shows the maximum reduction of the maximum transformer loading, compared to other scenarios, about 10.2% and 33.4%. The same scenario shows a decrease of the maximum voltage spread in about 10.2% and 6.5% (Figure 11 and Figure 14). The results in Figure 11 and Figure 14 show that there is no improvement in the line loadings as it increases in a range from 0.4% – 1.0% compared to the baseline scenario. The duration of maximum line overloading over 80% is about 10% - 15% of the whole simulation time. These results are reflected through the 50% PV and 75% PV variations results analysis.

On the thermal domain side the controller, under various heat export limitation conditions as well as target goals (control A and control B) maximizes up to 1692 MWh/year the heat production from PV surplus, covering totally the heat distribution losses but only partly the heat demand from Eisingen. Heat export limitations to the wider grid of Ulm have an effect on the storage design, showing a clearly decreased need for heat storage when heat produced with PV surplus can be directly exported to the wider grid of Ulm.

Annex 1: Skelleftea Thermal Side

The results from the simulation runs for the winter period (November to March) is reported in tabular form in the Annex 1

electricity price [€/MWh]	battery size [MW/MWh]	industry size [MW]	heat demand increase [%]	Strategy [-]	max eboiler output [MW]	heat demand [MWh]	heat losses [MWh]	biomass [MWh]	chp heat [MWh]	eboiler [MWh]	heatpump [MWh]
0_51	1	10	0	baseline	43.6	227133	12280	52803	141402	51647	0
0_51	1	10	0	control	45.3	227133	12265	22392	156748	25578	41103
0_51	5	10	0	control	45.3	227133	12265	22392	156748	25578	41103
0_51	10	10	0	control	45.3	227133	12265	22392	156748	25578	41103
0_51	1	20	0	baseline	43.6	227133	12280	52803	141402	51647	0
0_51	1	20	0	control	37.5	227133	12245	8346	152504	10815	74134
0_51	5	20	0	control	37.5	227133	12245	8346	152504	10815	74134
0_51	10	20	0	control	37.5	227133	12245	8346	152504	10815	74134
0_51	1	30	0	baseline	43.6	227133	12280	52803	141402	51647	0
0_51	1	30	0	control	25.4	227132	12199	4092	142163	2182	97309
0_51	5	30	0	control	25.4	227132	12199	4092	142163	2182	97309
0_51	10	30	0	control	25.4	227132	12199	4092	142163	2182	97309
0_51	1	40	0	baseline	43.6	227133	12280	52803	141402	51647	0
0_51	1	40	0	control	25.6	227132	12162	2539	130153	1145	111844
0_51	5	40	0	control	25.6	227132	12162	2539	130153	1145	111844
0_51	10	40	0	control	25.6	227132	12162	2539	130153	1145	111844
0_51	1	10	5	baseline	41.5	238488	12954	53553	140577	63157	0
0_51	1	10	5	control	49.3	238488	12901	30789	157210	25464	43763
0_51	5	10	5	control	49.3	238488	12901	30789	157210	25464	43763
0_51	10	10	5	control	49.3	238488	12901	30789	157210	25464	43763
0_51	1	20	5	baseline	41.5	238488	12954	53553	140577	63157	0
0_51	1	20	5	control	40.6	238488	12885	10786	153939	14692	77781
0_51	5	20	5	control	40.6	238488	12885	10786	153939	14692	77781
0_51	10	20	5	control	40.6	238488	12885	10786	153939	14692	77781
0_51	1	30	5	baseline	41.5	238488	12954	53553	140577	63157	0
0_51	1	30	5	control	29.9	238489	12851	5413	145898	3832	102021
0_51	5	30	5	control	29.9	238489	12851	5413	145898	3832	102021
0_51	10	30	5	control	29.9	238489	12851	5413	145898	3832	102021
0_51	1	40	5	baseline	41.5	238488	12954	53553	140577	63157	0
0_51	1	40	5	control	32.1	238488	12821	3797	136056	2213	115041
0_51	5	40	5	control	32.1	238488	12821	3797	136056	2213	115041
0_51	10	40	5	control	32.1	238488	12821	3797	136056	2213	115041
0_51	1	10	10	baseline	39.0	249845	13565	58998	142261	67395	0
0_51	1	10	10	control	48.0	249844	13500	38874	158019	25801	45895
0_51	5	10	10	control	48.0	249844	13500	38874	158019	25801	45895
0_51	10	10	10	control	48.0	249844	13500	38874	158019	25801	45895
0_51	1	20	10	baseline	39.0	249845	13565	58998	142261	67395	0
0_51	1	20	10	control	44.2	249844	13547	15396	155381	17099	80732

0_51	5	20	10	control	44.2	249844	13547	15396	155381	17099	80732
0_51	10	20	10	control	44.2	249844	13547	15396	155381	17099	80732
0_51	1	30	10	baseline	39.0	249845	13565	58998	142261	67395	0
0_51	1	30	10	control	34.3	249844	13500	6538	149135	6039	106852
0_51	5	30	10	control	34.3	249844	13500	6538	149135	6039	106852
0_51	10	30	10	control	34.3	249844	13500	6538	149135	6039	106852
0_51	1	40	10	baseline	39.0	249845	13565	58998	142261	67395	0
0_51	1	40	10	control	34.6	249844	13482	4423	141443	3601	119063
0_51	5	40	10	control	34.6	249844	13482	4423	141443	3601	119063
0_51	10	40	10	control	34.6	249844	13482	4423	141443	3601	119063
0_51	1	10	20	baseline	74.1	272556	14815	63283	154349	73736	0
0_51	1	10	20	control	58.4	272556	14787	46796	159315	37088	48193
0_51	5	10	20	control	58.4	272556	14787	46792	159311	37095	48193
0_51	10	10	20	control	58.4	272556	14787	46796	159315	37088	48193
0_51	1	20	20	baseline	74.1	272556	14815	63283	154349	73736	0
0_51	1	20	20	control	46.1	272556	14835	28446	155481	19040	88429
0_51	5	20	20	control	46.1	272556	14835	28446	155481	19040	88429
0_51	10	20	20	control	46.1	272556	14835	28446	155481	19040	88429
0_51	1	30	20	baseline	74.1	272556	14815	63283	154349	73736	0
0_51	1	30	20	control	43.5	272556	14804	12251	152316	10772	116025
0_51	5	30	20	control	43.5	272556	14804	12251	152316	10772	116025
0_51	10	30	20	control	43.5	272556	14804	12251	152316	10772	116025
0_51	1	40	20	baseline	74.1	272556	14815	63283	154349	73736	0
0_51	1	40	20	control	42.8	272556	14789	6809	148355	8902	127288
0_51	5	40	20	control	42.8	272556	14789	6809	148355	8902	127288
0_51	10	40	20	control	42.8	272556	14789	6809	148355	8902	127288
19_5	1	10	0	baseline	43.6	227133	12280	52803	141402	51647	0
19_5	1	10	0	control	41.8	227133	12265	22442	157533	24891	40954
19_5	5	10	0	control	41.8	227133	12265	22440	157534	24891	40955
19_5	10	10	0	control	41.8	227133	12265	22440	157532	24895	40954
19_5	1	20	0	baseline	43.6	227133	12280	52803	141402	51647	0
19_5	1	20	0	control	36.2	227133	12245	8338	153968	10148	73343
19_5	5	20	0	control	36.1	227133	12245	8340	154001	10142	73315
19_5	10	20	0	control	36.2	227133	12246	8338	154015	10163	73283
19_5	1	30	0	baseline	43.6	227133	12280	52803	141402	51647	0
19_5	1	30	0	control	25.1	227133	12198	4057	145831	1754	94094
19_5	5	30	0	control	25.1	227133	12198	4057	145831	1754	94094
19_5	10	30	0	control	25.1	227133	12198	4057	145831	1754	94094
19_5	1	40	0	baseline	43.6	227133	12280	52803	141402	51647	0
19_5	1	40	0	control	27.6	227132	12156	2120	136736	1120	105693
19_5	5	40	0	control	27.6	227132	12156	2120	136736	1120	105693
19_5	10	40	0	control	27.6	227132	12156	2120	136736	1120	105693
19_5	1	10	5	baseline	41.5	238488	12954	53553	140577	63157	0
19_5	1	10	5	control	49.3	238488	12902	31067	157789	24706	43662
19_5	5	10	5	control	49.3	238488	12902	31060	157788	24718	43659
19_5	10	10	5	control	49.3	238488	12902	31057	157800	24713	43654

19_5	1	20	5	baseline	41.5	238488	12954	53553	140577	63157	0
19_5	1	20	5	control	40.6	238488	12886	10772	155435	14031	76956
19_5	5	20	5	control	40.6	238488	12886	10769	155446	14018	76964
19_5	10	20	5	control	40.6	238488	12886	10769	155460	14020	76948
19_5	1	30	5	baseline	41.5	238488	12954	53553	140577	63157	0
19_5	1	30	5	control	30.1	238489	12851	5387	148975	3311	99483
19_5	5	30	5	control	30.1	238489	12851	5387	148975	3311	99483
19_5	10	30	5	control	30.1	238489	12851	5387	148975	3311	99483
19_5	1	40	5	baseline	41.5	238488	12954	53553	140577	63157	0
19_5	1	40	5	control	29.9	238488	12814	3739	141383	1783	110190
19_5	5	40	5	control	29.9	238488	12814	3739	141383	1783	110190
19_5	10	40	5	control	29.9	238488	12814	3739	141383	1783	110190
19_5	1	10	10	baseline	39.0	249845	13565	58998	142261	67395	0
19_5	1	10	10	control	45.5	249844	13503	39221	158557	24920	45894
19_5	5	10	10	control	45.5	249844	13503	39221	158557	24920	45894
19_5	10	10	10	control	45.5	249844	13503	39221	158557	24917	45897
19_5	1	20	10	baseline	39.0	249845	13565	58998	142261	67395	0
19_5	1	20	10	control	44.9	249844	13548	15389	156539	16495	80185
19_5	5	20	10	control	45.1	249844	13547	15391	156564	16463	80192
19_5	10	20	10	control	45.0	249844	13548	15388	156566	16461	80192
19_5	1	30	10	baseline	39.0	249845	13565	58998	142261	67395	0
19_5	1	30	10	control	34.5	249844	13502	6512	151756	5446	104849
19_5	5	30	10	control	34.5	249844	13502	6512	151756	5446	104849
19_5	10	30	10	control	34.5	249844	13502	6512	151756	5446	104849
19_5	1	40	10	baseline	39.0	249845	13565	58998	142261	67395	0
19_5	1	40	10	control	34.8	249844	13476	4381	145540	3200	115399
19_5	5	40	10	control	34.8	249844	13476	4381	145540	3200	115399
19_5	10	40	10	control	34.8	249844	13476	4381	145540	3200	115399
19_5	1	10	20	baseline	74.1	272556	14815	63283	154349	73736	0
19_5	1	10	20	control	58.4	272556	14788	47239	159864	36111	48172
19_5	5	10	20	control	58.4	272556	14788	47238	159856	36114	48180
19_5	10	10	20	control	58.4	272556	14788	47242	159851	36117	48180
19_5	1	20	20	baseline	74.1	272556	14815	63283	154349	73736	0
19_5	1	20	20	control	46.1	272556	14836	28663	156628	18227	87871
19_5	5	20	20	control	46.1	272556	14836	28662	156631	18233	87867
19_5	10	20	20	control	46.1	272556	14836	28663	156632	18248	87853
19_5	1	30	20	baseline	74.1	272556	14815	63283	154349	73736	0
19_5	1	30	20	control	43.4	272556	14806	12221	154541	10152	114445
19_5	5	30	20	control	43.4	272556	14805	12215	154544	10153	114451
19_5	10	30	20	control	43.4	272556	14805	12215	154544	10153	114451
19_5	1	40	20	baseline	74.1	272556	14815	63283	154349	73736	0
19_5	1	40	20	control	43.3	272556	14791	6776	151165	8338	125072
19_5	5	40	20	control	43.3	272556	14791	6776	151165	8338	125072
19_5	10	40	20	control	43.3	272556	14791	6776	151165	8338	125072

Annex 2: Skelleftea Electrical Side

The results from the simulation runs for the winter period (November to March) is reported in tabular form in the Annex 2

strat egy				contr ol	NL	MTL1	MTL2	DTL1	DTL2	MLL	DLL	MVS
Ind 10	bat 1	hd0	epr 1	b	3757.13 143	149.8 28	45.99 65	24.875	0	317.2 64	89.75	66.5 85
Ind 10	bat 1	hd0	epr 1	r	3250.61 055	78.08 7	99.90 3	0	5.7638 89	315.1 06	38.611	69.6 7
Ind 10	bat 1	hd0	epr 2	b	3120.07 374	45.99 6	149.8 3	0	24.875	317.2 6	89.75	66.5 9
Ind 10	bat 1	hd0	epr 2	r	3224.21 125	72.27 1	146.9 5	0	9.2847 22	289.0 5	38.15	62.9 3
Ind 10	bat 1	hd5	epr 1	b	3494.64 035	149.3 4	46.00 36	30.375	0	314.6 72	92.277 778	64.0 94
Ind 10	bat 1	hd5	epr 1	r	3350.50 954	78.10 1	171.5 6	0	10.458 333	334.8 1	37.625	76.4 7
Ind 10	bat 1	hd5	epr 2	b	3494.64 214	46.00 4	149.3 4	0	30.375	314.6 7	92.277 778	64.1
Ind 10	bat 1	hd5	epr 2	r	3323.40 374	72.26 4	171.5 6	0	9.9097 22	334.8 1	36.868 056	76.4 7
Ind 10	bat 1	hd1 0	epr 1	b	3757.13 768	46.00 1	138.4 6	0	44.555 556	306.2 1	86.972 222	60.1 8
Ind 10	bat 1	hd1 0	epr 1	r	3412.14 792	78.10 4	159.2	0	10.312 5	322.9 7	38.840 278	72.8
Ind 10	bat 1	hd1 0	epr 2	b	3757.13 768	46.00 1	138.4 6	0	44.555 556	306.2 1	86.972 222	60.1 8
Ind 10	bat 1	hd1 0	epr 2	r	3385.41 034	73.28 8	157.0 1	0	9.7708 33	322.9 7	37.777 778	70.2 3
Ind 10	bat 1	hd2 0	epr 1	b	4249.76 897	46	235.6 3	0	34.555 556	497.3 1	92.506 944	122. 93
Ind 10	bat 1	hd2 0	epr 1	r	3798.85 798	195.2 95	78.14 51	17.034 722	0	405.4 28	52.409 722	93.8 49
Ind 10	bat 1	hd2 0	epr 2	b	4249.76 897	46	235.6 3	0	34.555 556	497.3 1	92.506 944	122. 93
Ind 10	bat 1	hd2 0	epr 2	r	3765.85 34	73.28 7	195.3	0	16.340 278	405.4 3	51.451 389	93.8 4
Ind 10	bat 5	hd0	epr 1	r	3260.58 43	159.4 06	100.8 64	9.6944 44	0.7222 22	315.1 05	38.611 111	69.6 7
Ind 10	bat 5	hd0	epr 2	r	3226.23 366	90.80 9	146.9 2	0.1041 67	9.2083 33	289.2 6	38.145 833	62.9 1
Ind 10	bat 5	hd5	epr 1	r	3360.30 34	100.8 8	171.5 6	0.7916 67	10.458 333	334.8 6	37.555 556	76.4 6
Ind 10	bat 5	hd5	epr 2	r	3325.85 772	91.81 7	171.5 6	0.0972 22	9.9722 22	334.8 6	36.881 944	76.4 6
Ind 10	bat 5	hd1 0	epr 1	r	3421.72 19	100.8 9	159.2	0.8541 67	10.305 556	322.9 7	38.812 5	72.8
Ind 10	bat 5	hd1 0	epr 2	r	3387.26 282	95.65 5	157.0 1	0.1041 67	9.7777 78	322.9 7	37.770 833	70.2 3
Ind 10	bat 5	hd2 0	epr 1	r	3808.86 011	100.9 4	195.2 9	0.9444 44	17.041 667	405.4 3	52.458 333	93.8 5
Ind 10	bat 5	hd2 0	epr 2	r	3768.17 152	95.65 4	195.3	0.1041 67	16.361 111	405.4 3	51.534 722	93.8 4
Ind	bat	hd0	epr	r	3286.43	127.7	159.4	1.6736	9.6944	315.1	38.645	69.6

10	10		1		22	8	1	11	44	1	833	7
Ind 10	bat 10	hd0	epr 2	r	3230.84 093	108.2 3	146.8 4	0.3541 67	9.1736 11	289.9 2	38.173 611	62.8 6
Ind 10	bat 10	hd5	epr 1	r	3385.63 599	127.8	171.5 1	1.75	10.458 333	335.2 2	37.583 333	76.4 3
Ind 10	bat 10	hd5	epr 2	r	3330.02 678	108.5 9	171.5 1	0.3194 44	9.9375	335.2 2	36.909 722	76.4 3
Ind 10	bat 10	hd1 0	epr 1	r	3446.95 506	127.8 1	159.2	1.9027 78	10.277 778	322.9 7	38.819 444	72.8
Ind 10	bat 10	hd1 0	epr 2	r	3391.28 251	108.5 9	157.0 1	0.2847 22	9.7708 33	322.9 7	37.763 889	70.2 3
Ind 10	bat 10	hd2 0	epr 1	r	3833.74 448	127.8 6	195.2 9	1.9861 11	17.048 611	405.4 3	52.451 389	93.8 5
Ind 10	bat 10	hd2 0	epr 2	r	3771.55 112	108.4 9	195.3	0.2708 33	16.298 611	405.4 3	51.423 611	93.8 4
Ind 20	bat 1	hd0	epr 1	b	5629.09 248	85.47 3	151.3 2	100	25.611 111	305.2 1	80.166 667	66.3 1
Ind 20	bat 1	hd0	epr 1	r	7272.97 738	133.8 1	140.3 3	99.979 167	2.1805 56	247.1	13.465 278	57.4 2
Ind 20	bat 1	hd0	epr 2	b	5629.09 248	85.47 3	151.3 2	100	25.611 111	305.2 1	80.166 667	66.3 1
Ind 20	bat 1	hd0	epr 2	r	7224.95 023	134.2 9	136.5 9	99.979 167	1.7916 67	248.2 8	12.861 111	55.0 8
Ind 20	bat 1	hd5	epr 1	b	5983.10 213	85.48 3	150.8 5	100	30.930 556	302.6 1	88.416 667	63.9 3
Ind 20	bat 1	hd5	epr 1	r	7484.90 24	136.9 2	149.6 9	99.979 167	4.0486 11	275.0 3	18.388 889	62.6 8
Ind 20	bat 1	hd5	epr 2	b	5983.10 213	85.48 3	150.8 5	100	30.930 556	302.6 1	88.416 667	63.9 3
Ind 20	bat 1	hd5	epr 2	r	7433.09 898	135.9 9	149.7 6	99.979 167	3.6111 11	275.3 2	17.881 944	62.6 5
Ind 20	bat 1	hd1 0	epr 1	b	6230.94 324	140.0 09	85.47 5	45.666 667	100	294.1 9	83.736 111	59.6 05
Ind 20	bat 1	hd1 0	epr 1	r	7642.54 644	160.0 21	138.3 81	6.5	99.986 111	296.7 68	20.562 5	68.8 65
Ind 20	bat 1	hd1 0	epr 2	b	6230.95 12	85.47 5	140.0 1	100	45.666 667	294.1 9	83.736 111	59.6 1
Ind 20	bat 1	hd1 0	epr 2	r	7602.72 18	138.3 8	162.1 5	99.986 111	5.9861 11	300.9 8	20.138 889	70.1 8
Ind 20	bat 1	hd2 0	epr 1	b	6671.16 683	85.47 2	236.9 3	100	37.604 167	485.2 3	87.840 278	122. 71
Ind 20	bat 1	hd2 0	epr 1	r	8024.52 063	138.4 6	164.5 8	99.993 056	9.4027 78	299.7 3	22.104 167	72.0 6
Ind 20	bat 1	hd2 0	epr 2	b	6671.16 683	85.47 2	236.9 3	100	37.604 167	485.2 3	87.840 278	122. 71
Ind 20	bat 1	hd2 0	epr 2	r	7974.53 31	138.4 2	164.6	99.993 056	8.6875	299.7 8	21.666 667	72.0 8
Ind 20	bat 5	hd0	epr 1	r	7276.46 474	153.5 5	140.3 3	99.798 611	2.1736 11	247.1	13.493 056	57.9 3
Ind 20	bat 5	hd0	epr 2	r	7226.99 917	153.5 5	136.0 8	99.736 111	1.8472 22	247.0 3	12.770 833	55.4 1
Ind 20	bat 5	hd5	epr 1	r	7488.43 42	156.5	149.6 9	99.840 278	4.0347 22	275.0 3	18.347 222	63.1 9
Ind 20	bat 5	hd5	epr 2	r	7436.65 312	154.0 2	149.7 6	99.798 611	3.6319 44	275.3 1	17.798 611	63.1 6
Ind 20	bat 5	hd1 0	epr 1	r	7645.86 401	157.9 9	160.0 2	99.854 167	6.4930 56	296.7 7	20.555 556	69.3 7

Ind 20	bat 5	hd1 0	epr 2	r	7605.39 229	157.9 9	162.8 1	99.784 722	5.9305 56	302.0 6	20.131 944	70.9 9
Ind 20	bat 5	hd2 0	epr 1	r	8027.58 13	158.0 6	164.5 7	99.833 333	9.3888 89	299.7 7	22.131 944	72.5 6
Ind 20	bat 5	hd2 0	epr 2	r	7977.63 062	158.0 3	164.5 9	99.847 222	8.6875	299.8 2	21.673 611	72.5 7
Ind 20	bat 10	hd0	epr 1	r	7285.26 228	176.7 2	140.3 3	99.520 833	2.1736 11	247.1	13.541 667	58.0 1
Ind 20	bat 10	hd0	epr 2	r	7234.50 285	176.7 2	136.5 9	99.451 389	1.8055 56	248.2 8	12.847 222	55.6 7
Ind 20	bat 10	hd5	epr 1	r	7497.37 807	178.8 4	149.6 9	99.527 778	4.0347 22	275.0 3	18.368 056	63.2 7
Ind 20	bat 10	hd5	epr 2	r	7985.32 672	180.9 2	164.5 9	99.638 889	8.7013 89	299.8 7	21.743 056	72.6 4
Ind 20	bat 10	hd1 0	epr 1	r	7654.70 802	180.8 6	160.0 2	99.590 278	6.4791 67	296.7 7	20.576 389	69.4 5
Ind 20	bat 10	hd1 0	epr 2	r	7613.78 875	180.8 6	162.3 5	99.541 667	6	300.9 1	20.013 889	70.9
Ind 20	bat 10	hd2 0	epr 1	r	8036.07 464	180.9 2	164.5 7	99.638 889	9.3888 89	299.8 2	22.166 667	72.6 2
Ind 20	bat 10	hd2 0	epr 2	r	7985.32 672	180.9 2	164.5 9	99.638 889	8.7013 89	299.8 7	21.743 056	72.6 4
Ind 30	bat 1	hd0	epr 1	b	9565.47 798	122.2 9	152.7 4	100	27.305 556	293.7 7	63.465 278	66.0 1
Ind 30	bat 1	hd0	epr 1	r	13036.3 485	187.1 7	105.3 2	100	0.4722 22	168.1 6	1.4583 33	38.4 8
Ind 30	bat 1	hd0	epr 2	b	9565.47 798	122.2 9	152.7 4	100	27.305 556	293.7 7	63.465 278	66.0 1
Ind 30	bat 1	hd0	epr 2	r	12853.6 56	187.6 1	104.8 8	100	0.4097 22	167.5 4	1.3263 89	38.1 3
Ind 30	bat 1	hd5	epr 1	b	9899.46 16	122.3	152.2 8	100	31.555 556	291.1 4	85.937 5	63.7 3
Ind 30	bat 1	hd5	epr 1	r	13257.1 583	185.8 8	118.9 2	100	1.0277 78	195.5 5	2.9027 78	45.6 4
Ind 30	bat 1	hd5	epr 2	b	9899.46 16	122.3	152.2 8	100	31.555 556	291.1 4	85.937 5	63.7 3
Ind 30	bat 1	hd5	epr 2	r	13107.3 807	185.8 8	119.6 7	100	0.8472 22	197.2 1	2.5208 33	46
Ind 30	bat 1	hd1 0	epr 1	b	10133.4 463	122.2 9	141.4 7	100	47.277 778	282.7 3	80.875	59.0 5
Ind 30	bat 1	hd1 0	epr 1	r	13498.3 779	186.0 5	132.4 3	100	1.8541 67	223.2 1	4.3125	52.9 8
Ind 30	bat 1	hd1 0	epr 2	b	10133.4 463	122.2 9	141.4 7	100	47.277 778	282.7 3	80.875	59.0 5
Ind 30	bat 1	hd1 0	epr 2	r	13375.9 219	185.7 8	133.1 3	100	1.4652 78	224.7 7	3.7847 22	53.3 2
Ind 30	bat 1	hd2 0	epr 1	b	10528.2 529	122.2 8	238.1	100	41.437 5	473.5	84.701 389	122. 39
Ind 30	bat 1	hd2 0	epr 1	r	13990.8 173	185.6 6	159.6 1	100	3.5625	279.1 4	10.416 667	68.7 4
Ind 30	bat 1	hd2 0	epr 2	b	10528.2 529	122.2 8	238.1	100	41.437 5	473.5	84.701 389	122. 39
Ind 30	bat 1	hd2 0	epr 2	r	13888.5 203	187.8 8	159.1	100	3.1805 56	278.0 4	9.9652 78	68.4 8
Ind 30	bat 5	hd0	epr 1	r	13038.2 153	203.7 8	105.3 2	100	0.4722 22	168.1 6	1.4722 22	39.5 3
Ind	bat	hd0	epr	r	12855.5	204.1	104.8	100	0.4097	167.5	1.3263	39.1

30	5		2		352	9	8		22	4	89	8
Ind 30	bat 5	hd5	epr 1	r	13259.0 603	201.6 6	118.9 2	100	1.0277 78	195.5 5	2.9027 78	46.6 9
Ind 30	bat 5	hd5	epr 2	r	13109.2 845	198.8 4	119.6 7	100	0.8472 22	197.2 1	2.5208 33	47.0 5
Ind 30	bat 5	hd1 0	epr 1	r	13500.2 063	202.7 7	132.4 3	100	1.8541 67	223.2 1	4.3125	54.0 3
Ind 30	bat 5	hd1 0	epr 2	r	13377.7 988	200.6 7	133.1 3	100	1.4652 78	224.7 7	3.7986 11	54.3 7
Ind 30	bat 5	hd2 0	epr 1	r	13992.4 977	201.8 5	159.6 1	100	3.5555 56	279.1 4	10.437 5	69.7 9
Ind 30	bat 5	hd2 0	epr 2	r	13890.5 394	204.4 4	159.1	100	3.1666 67	278.0 4	10.020 833	69.5 3
Ind 30	bat 10	hd0	epr 1	r	13045.2 048	223.0 8	105.3 2	99.951 389	0.4722 22	168.1 6	1.4791 67	40.4 1
Ind 30	bat 10	hd0	epr 2	r	12862.3 568	223.4 5	104.8 8	99.944 444	0.4097 22	167.5 4	1.3263 89	40.0 6
Ind 30	bat 10	hd5	epr 1	r	13265.9 494	220.7 7	118.9 2	99.951 389	1.0277 78	195.5 5	2.9166 67	47.5 7
Ind 30	bat 10	hd5	epr 2	r	13115.9 963	218.5 8	119.6 7	99.965 278	0.8472 22	197.2 1	2.5208 33	47.9 3
Ind 30	bat 10	hd1 0	epr 1	r	13506.8 025	222.2	132.4 3	99.958 333	1.8541 67	223.2 1	4.3263 89	54.9 1
Ind 30	bat 10	hd1 0	epr 2	r	13384.4 371	220.2 2	133.1 3	99.965 278	1.4652 78	224.7 7	3.8333 33	55.2 5
Ind 30	bat 10	hd2 0	epr 1	r	13998.8 737	221.3 2	159.6 1	99.979 167	3.5555 56	279.1 4	10.437 5	70.6 7
Ind 30	bat 10	hd2 0	epr 2	r	13897.1 089	223.6 7	159.1	99.986 111	3.1597 22	278.0 4	10.083 333	70.4 1
Ind 40	bat 1	hd0	epr 1	b	14498.2 246	155.8 9	154.0 6	100	29.270 833	283.1 5	46.597 222	65.6 8
Ind 40	bat 1	hd0	epr 1	r	19452.3 059	221.8 5	107.5 7	100	0.3472 22	160.6 7	0.4027 78	39.2
Ind 40	bat 1	hd0	epr 2	b	14498.2 246	155.8 9	154.0 6	100	29.270 833	283.1 5	46.597 222	65.6 8
Ind 40	bat 1	hd0	epr 2	r	19057.7 777	221.5 6	108.4 5	100	0.5138 89	172.5 2	0.6597 22	42.8 6
Ind 40	bat 1	hd5	epr 1	b	14813.0 548	155.9	153.6	100	31.965 278	280.4 7	81.409 722	63.4 9
Ind 40	bat 1	hd5	epr 1	r	19586.7 55	222.6 5	124.9 7	100	0.5763 89	193.0 6	0.9375	53.0 2
Ind 40	bat 1	hd5	epr 2	b	14813.0 548	155.9	153.6	100	31.965 278	280.4 7	81.409 722	63.4 9
Ind 40	bat 1	hd5	epr 2	r	19271.3 252	222.6 4	120.3 2	100	0.4166 67	186.1 7	0.7222 22	46.0 7
Ind 40	bat 1	hd1 0	epr 1	b	15034.2 54	155.8 8	142.8 2	100	49.006 944	272.0 4	75.409 722	58.5 3
Ind 40	bat 1	hd1 0	epr 1	r	19772.4 304	224.1 1	134.6 1	100	0.8125	215.4 9	1.9583 33	53.8 7
Ind 40	bat 1	hd1 0	epr 2	b	15034.2 54	155.8 8	142.8 2	100	49.006 944	272.0 4	75.409 722	58.5 3
Ind 40	bat 1	hd1 0	epr 2	r	19535.0 863	222.6 5	135.1 2	100	0.7083 33	216.6 5	1.8263 89	54.1 1
Ind 40	bat 1	hd2 0	epr 1	b	15391.0 544	155.8 7	239.1 1	100	45.118 056	462.3 9	80.361 111	122
Ind 40	bat 1	hd2 0	epr 1	r	20229.7 756	222.5 5	159.3 5	100	3.6041 67	266.9 9	6.2013 89	67.9 9

Ind 40	bat 1	hd2 0	epr 2	b	15391.0 544	155.8 7	239.1 1	100	45.118 056	462.3 9	80.361 111	122
Ind 40	bat 1	hd2 0	epr 2	r	20076.8 004	224.5 6	160.0 4	100	3.2152 78	267.9 5	5.7777 78	68.7 2
Ind 40	bat 5	hd0	epr 1	r	19453.2 217	235.1 2	107.5 7	100	0.3472 22	160.6 7	0.4027 78	40.6 3
Ind 40	bat 5	hd0	epr 2	r	19058.8 661	234.3 9	108.4 5	100	0.5138 89	172.5 2	0.6597 22	44.3 1
Ind 40	bat 5	hd5	epr 1	r	19587.5 924	237	124.9 7	100	0.5763 89	193.0 6	0.9375	54.4 5
Ind 40	bat 5	hd5	epr 2	r	19272.3 45	236.9 9	120.3 2	100	0.4166 67	186.1 7	0.7222 22	47.5
Ind 40	bat 5	hd1 0	epr 1	r	19773.3 423	238.2 6	134.6 1	100	0.8125	215.4 9	1.9652 78	55.3
Ind 40	bat 5	hd1 0	epr 2	r	19536.0 728	237	135.1 2	100	0.7083 33	216.6 5	1.8263 89	55.5 4
Ind 40	bat 5	hd2 0	epr 1	r	20230.6 422	236.6 1	159.3 5	100	3.6041 67	266.9 9	6.2152 78	69.4 4
Ind 40	bat 5	hd2 0	epr 2	r	20077.6 569	238.8 4	160.0 4	100	3.2152 78	267.9 5	5.7916 67	70.1 7
Ind 40	bat 10	hd0	epr 1	r	19456.8 066	251.9 5	107.5 7	100	0.3472 22	160.6 7	0.4027 78	42.1 3
Ind 40	bat 10	hd0	epr 2	r	19062.8 093	251.2 7	108.4 5	100	0.5138 89	172.5 2	0.6597 22	45.8 1
Ind 40	bat 10	hd5	epr 1	r	19591.0 458	253.6 4	124.9 7	100	0.5763 89	193.0 6	0.9444 44	55.9 5
Ind 40	bat 10	hd5	epr 2	r	19276.1 466	253.6 3	120.3 2	100	0.4166 67	186.1 7	0.7222 22	49
Ind 40	bat 10	hd1 0	epr 1	r	19776.8 605	254.6 7	134.6 1	100	0.8125	215.4 9	1.9722 22	56.8
Ind 40	bat 10	hd1 0	epr 2	r	19539.7 28	253.6 4	135.1 2	100	0.7083 33	216.6 5	1.8333 33	57.0 4
Ind 40	bat 10	hd2 0	epr 1	r	20233.9 408	252.9 7	159.3 5	100	3.5902 78	266.9 9	6.2291 67	70.9 4
Ind 40	bat 10	hd2 0	epr 2	r	20081.0 344	255.4	160.0 4	100	3.2013 89	267.9 5	5.8125	71.6 7

Annex 3: Ulm Thermal Side

The results from the simulation runs of the first six months of the year are reported in tabular form in the Annex 3.

<i>Sim name</i>	Qprod_ulm	Erod	Qcons_ein	Qcons_ulm	Qlosses
<i>UNIT</i>	[MWh]	[MWh]	[MWh]	[MWh]	[MWh]
PV50 hgridInfinite_baseline	4955	0	4090	0	859
hgrid100_controlA	4073	892	4081	25	841
hgrid200_controlA	4135	1020	4090	170	879
hgrid300_controlA	4193	1135	4090	315	893
hgrid400_controlA DaRisimulare	- 4193	1135	4090	315	893
hgrid500_controlA	4304	1231	4090	521	887
hgridInfinite_controlA	4410	1233	4090	636	878
hgrid100_controlB	4222	758	4090	7	861
hgrid200_controlB	4225	819	4090	68	867
hgrid300_controlB	4235	862	4090	116	873
hgrid400_controlB	4245	893	4090	151	878
hgrid500_controlB	4252	919	4090	179	881
hgridInfinite_controlB	4263	956	4090	221	885
PV75 hgridInfinite_baseline	4955	0	4090	0	859
hgrid100_controlA	3925	1050	4087	25	844
hgrid200_controlA	3971	1222	4091	200	884
hgrid300_controlA	4027	1397	4091	391	904
hgrid400_controlA	4085	1510	4090	546	907
hgrid500_controlA	4139	1582	4090	675	901
hgridInfinite_controlA	4293	1612	4090	881	883
hgrid100_controlB	4089	896	4090	8	863
hgrid200_controlB	4089	986	4090	93	872
hgrid300_controlB	4103	1049	4090	161	880
hgrid400_controlB	4117	1095	4090	213	886
hgrid500_controlB	4128	1133	4090	255	890
hgridInfinite_controlB	4145	1197	4091	324	896

Annex 4: Ulm Electrical Side

The results from the simulation runs of the first six months of the year are reported in tabular form in the Annex 4.

PV50%

strategy	hg	NL	MTL	DTL	MLL	DLL	MVS
[-]	[-]	[%]	[%]	[%]	[%]	[%]	[%]
Baseline	Hg infinite	60.8	128.33	8.25	140.93	10.23	105.93
Control A	Hg infinite	50.3	102.46	0.003	142.27	10.28	95.13
Control A	Hg 100	53.71	128	2.98	142.27	10.28	105.63
Control A	Hg 200	52.5	128.33	1.904	141.94	10.27	105.93
Control A	Hg 300	51.356	123.47	0.98	142.27	10.27	102.73
Control A	Hg 400	51.32	118.02	0.965	142.27	10.27	97.93
Control A	Hg 500	50.31	115.38	0.02	142.27	10.28	97.73
Baseline	Hg infinite	60.8	128.33	8.25	140.93	10.23	105.93
Control B	Hg 100	53.1	128.33	2.53	141.94	10.28	105.93
Control B	Hg 200	55.044	128.33	4.19	141.61	10.27	105.93
Control B	Hg 300	54.5	128.33	3.73	141.61	10.27	105.93
Control B	Hg 400	54.04	128.33	3.362	141.94	10.27	105.93
Control B	Hg 500	53.75	128.33	3.11	141.94	10.28	105.93
Control B	Hg infinite	53.52	128.33	2.914	141.61	10.285	105.93

PV 75%

strategy	hg	NL	MTL	DTL	MLL	DLL	MVS
[-]	[-]	[%]	[%]	[%]	[%]	[%]	[%]
Baseline	Hg infinite	112.25	185.08	13.83	204.97	15.5	142.73
Control A	Hg infinite	90.8	123.25	0.0542	206.43	15.6	133.43
Control A	Hg 100	99.8	185.08	5.91	205.85	15.5	142.73
Control A	Hg 200	97.3	184.45	4.238	206.43	15.55	142.43

Control A	Hg 300	94.5	174.79	2.48	206.43	15.55	136.43
Control A	Hg 400	92.3	172.8	1.09	206.43	15.55	135.23
Control A	Hg 500	91.11	162.1	0.3	206.43	15.6	133.43
Baseline	Hg infinite	112.25	185.08	13.83	204.97	15.5	142.73
Control B	Hg 100	97.5	185.08	4.435	205.85	15.54	142.73
Control B	Hg 200	102.12	184.53	7.44	206.43	15.51	142.43
Control B	Hg 300	100.8	185.08	6.58	205.85	15.53	142.73
Control B	Hg 400	99.88	185.08	5.985	205.85	15.522	142.73
Control B	Hg 500	99.22	185.08	5.531	205.85	15.54	142.73
Control B	Hg infinite	98.64	184.53	5.188	206.43	15.55	142.43

Annex 5: Ulm Power to Gas scenario

Electrical grid model

Inside the project for both test sites, Eisingen and Hittistetten, a simulation model in power factory was built by HSU. Therefore, the real network structure was used and implemented in the model. To create a time course in 15 minute steps for a whole year standard load profiles (SLP) of the distribution grid operator (DSO) were used [2]. SLP's are the state of the art procedure of all DSO's for the estimation of the customers demand. SLP's are categorized in several groups like household, industry or agriculture. With the information from Stadtwerke Ulm/Neu-Ulm Netze GmbH the customers in the test sites were categorized into these groups. In addition every value of the SLP has to be multiplied by yearly energy demand of the customers.

$$P_{customer} = SLP * E_{customer}$$

With

$P_{customer}$: electrical power of the customer in kW

SLP: Standard Load Profile in kW/kWh

$E_{customer}$: yearly Energy demand of the customer in kWh

For the calculation of the PV-feed in a matlab library, PVlib [5], was used. Therefore various input parameters are necessary which are listed in Table 2. For the different irradiations data from CAMS-irradiation-service [6] was used.

Table 2: input parameter for simulation model of the test sites

	Element	Parameter	unit
Grid structure	Cables	Cable Length Cable size [mm ²]	m mm ²
	Transformer	Nominal power Transformer type	kW
Demand	Households	Standard load profiles	kW/kWh
	Industry	Yearly energy demand	kWh
	Agriculture		
PV-feed in	Photovoltaik systems	Nominal power	kWp
		Orientation	°
	Irradiation	Inclination	°
		Global horizontal irradiation	W/m ²
		Beam normal irradiation	W/m ²
Temperature	Diffuse horizontal irradiation	W/m ²	
	Temperature	°C	

Gas grid model

The Figure 23 shows the way of the data preparation for the gas grid simulation model. . The data base sources are an extraction from LIDS and SAP of the Stadtwerke Ulm/Neu-Ulm Netze GmbH. HSU prepared the topology and the demand of the customers for the simulation in STANET by using QGIS

(geo information system tool) and KNIME (an open source data mining tool). With the transferred data into STANET is it possible to create almost automated a simulation model of the grid.




Figure 23: data preparation for the automatically creation of the gas grid simulation model

Figure 24 visualise the two grid models and show the structure. The models cover a bigger area than the test sides. This is caused of the connection points to the higher pressure grid level. Like the Transformer station in the electrical grid.




Figure 24: Overview of the two gas grid models from sides Hittisteten (left), Einsingen (middle) and the zoomed test side in Einsingen (right)

Table 1 gives a feeling for the range of the two gas grid models. Einsingen is for every Parameter nearly doubled as Hittistetten. However, with the developed data process is it not that big difference to model such grid models for simulation and analysis. That is also an important tool for planning and operating the gas grid by the DSO.

Table 1 Key values of the two gas grid models at the area at Eisingen and Hittistetten

Parameter	Eisingen	Hittistetten
Number of Nodes	1,106	522
Number of Pipes	1,133	559
Number of Pressure controller	2	1
Number of annual demand from meter	1,130	97
Pipe Volume [m ³]	379	59
Pipe length [km]	46,1	10,4

Electrolyzer

For the conversion from electrical power to hydrogen, the technical parameter of the Silyzer 100 was used in the simulation. The silyzer is developed by Siemens and purchasable over the company [7]. The parameters of the Silyzer 100 are listed in Table 3. The produced hydrogen was calculated by following formula:

$$H_2 = 2.113 * \exp(-0.001648 * P_{el})$$

H₂: produced hydrogen in kg

P_{el}: electrical surplus in kW

Table 3: Parameters of the Silyzer 100

Parameter	Value	unit
Nominal power	100	kW
efficiency	50 – 60	%
Nominal power gas	20.022	Nm ³ /h
Hydrogen production	18	Kg/MW
Output pressure	50	Bar
Maximum power (overload)	300	%
Warm start	<10	Sec
Life time	>60000	h

A Matlab script did the calculation of the produced hydrogen. For the script only the loadflow at the transformer and the number of used electrolyze stacks are needed. If there, more than one stack is necessary they are connected in parallel and the consumption, that all stacks consume the same power, was made. For the number of stacks the maximum PV-feed in of the year was precise and two approaches were done. The first is that the electrolyzer should work within the nominal power and the second was the utilization of the maximum overload of 300 %. The second variation shows worse efficiency and less investment costs. For the conversion of H₂ in kg into H₂ the calorific value 33.3 in kWh/kg [4], a) as used.

Methanation

Based on the out coming hydrogen (H₂) from the electrolysis will be the methanation output be calculated. The methanation is much less flexible than the electrolysis. For a first assumption, an easy

to handle definition was fixed. The assumed nominal power of the methanation is the average value of the maximum H₂ production (Energy) over day and the methane production within 12 h ($P_{CH_4_nominal} = E_{H_2_max_day}/12h$). That represent the approach that the hydrogen production by electrical PV power and electrolysis over the day will be produced during the night to methane. Table 4 gives an over view of the resulting nominal methanation power and the size of the hydrogen buffer storage for the different control strategies. *Table 4* gives an overview of the resulting nominal methanation power and the size of the hydrogen buffer storage for the different control strategies.

$$\dot{Q}_{CH_4} = \frac{\hat{Q}_{H_2,1d}}{12h}$$

$\hat{Q}_{H_2,1d}$: Maximum daily hydrogen production

\dot{Q}_{CH_4} : Calculated input nominal power of the methanation

The volume of a hydrogen tank can be calculated by the following equation:

$$V_1 = \frac{V_{standard} \cdot p_{standard}}{p_1}$$

p: Pressure

V: Volume

p_1 is the aimed pressure of the buffer hydrogen storage (e.g. 750 bar). $p_{standard}$ is the standard pressure value for the standard conditions of the gas.

The controller of the methanation starts working if the hydrogen buffer storage has enough hydrogen for one hour production and stop the methane production if the charge drops under this level. The efficiency of the methanation process was fixed to 60 %.

With this approach is the volume of a hydrogen buffer storage in Einsingen from 26,031 Nm³ up to 43,159 Nm³ and in Hittistetten from 102,040 Nm³ up to 160,884 Nm³. For a reduction of the simulation effort and time is a reduction of the variation based on a technical and economic point of view done. All volumes at 750 bars in *Table 4* are in a technical dimension that is realistic to handle. The investment costs will be more economic for a bigger hydrogen buffer storage instead a methanation with a higher nominal power. The hydrogen production is decreasing with a lower number of stacks. This is caused by the lesser efficiency. More losses means more heat production in the process. Because of the Power to Heat approach from hybrid scenario 1 in the same area is it not possible to use the heat direct there. Only the additional usage of the DHN can make It possible to transport the heat power in other areas of the city where it could be used. However, the DHN is not in the story line of hybrid scenario 1.

Table 4: results of the power to gas analysis

Test area	Scenario	Nominal methanation power [kW] left, [Nm ³ /h] right		Hydrogen buffer storage capacity [Nm ³]	Hydrogen buffer storage (tank) [m ³] at 750 bar
Einsingen	Control 3, 3 Stacks, 50%-PV	530.27	3.981	26,031	35
Einsingen	Control 4, 3 Stacks, 50%-PV	532.13	3.995	26,040	34.7
Einsingen	Control 3, 5 Stacks, 75%-PV	916.68	6.882	42,845	57.1
Einsingen	Control 4, 5 Stacks, 75%-PV	917.48	6.888	43,159	57.5
Einsingen	Control 3, 13 Stacks, 75%-PV	1937.39	14,545	35,313	47.08
Einsingen	Control 4, 13 Stacks, 75%-PV	1934.06	14,52	35,574	47.43
Hittistetten	11 Stacks, 50%-PV	1662.34	12.48	130,064	173.41
Hittistetten	4 Stacks, 50%-PV	829.84	6.23	102,040	136.05
Hittistetten	13 Stacks, 75%-PV	1984.68	14.9	160,884	214.51
Hittistetten	4 Stacks, 75%-PV	865.80	6.5	110,825	147,76

References

- [1] BDEW Bundesverband der Energie- und Wasserwirtschaft e.V.; Verband kommunaler Unternehmen e.V. (VKU); GEODE – Groupement Européen des entreprises et Organismes de Distribution d'Énergie, EWIV; BDEW/VKU/GEODE Leitfadens; Berlin, 30. Juni 2011
- [2] Stadtwerke Ulm/Neu-Ulm Netze GmbH, Gesichtet 16.09.2016
<https://www.ulm-netze.de/services/downloads.html>
- [3] David E. Stakic, Holger Ruf, Konstantin Ditz, Daniel Funk, Gerd Heilscher, Florian Meier; Simulation of Local Energy Surplus Usage in Hybrid Grids With a High PV Penetration Rate; EU PVSEC 2016, Munich; Year 2016; Poster + Paper
- [4] Dr. Rüdiger Paschotta (G+), RP Photonics Consulting GmbH; RP-Energie-Lexikon; 78073, Bad Dürkheim, Germany, 23.12.2016
- a) <https://www.energie-lexikon.info/wasserstoff.html>
- b) <https://www.energie-lexikon.info/methan.html?s=ak>
- [5] Sandia Corporation, 23.12.2016, <https://pvpmc.sandia.gov/>
- [6] SoDa; Center for Observation, Impacts, Energy (O.I.E.) 1 rue Claude Daunesse BP 207 06904 Sophia Antipolis Cedex – France; 23.12.2016
<http://www.soda-pro.com/web-services#radiation>
- [7] Siemens AG; SILYZER; Ideen für eine nachhaltige Zukunft: Der SILYZER öffnet Perspektiven; 23.12.2016
<http://www.industry.siemens.com/topics/global/de/pem-elektrolyseur/silyzer/seiten/silyzer.aspx>
- [8] DENA, power-to-gas Plattform, 23.12.2016 www.powertogas.info
- [9] Markus Lehner, Robert Tichler, Horst Steinmüller, Markus Koppe; Springer Cham Heidelberg New York Dordrecht London; Power-to-Gas: Technology and Business Models; ISBN 978-3-319-03994-7; Year 2014

Disclaimer

The OrPHEuS project is co-funded by the European Commission under the 7th Framework Programme “Smart Cities” 2013.

The sole responsibility for the content of this publication lies with the authors. It does not necessarily reflect the opinion of the European Commission.

The European Commission is not responsible for any use that may be made of the information contained therein.

Contacts

Project coordinator

Ingrid Weiss, Simon Challet & Silvia Caneva @ WIP – Renewable Energies

Sylvensteinstrasse 2, Munich, Germany

Email: Ingrid.weiss@wip-munich.de / Telephone: 0049 (0) 720 12 741

Email: silvia.caneva@wip-munich.de / Telephone: 0049 (0) 720 12 733

Email: simon.challet@wip-munich.de / Telephone: 0049 (0) 720 12 740

WP Leader

Helfried Brunner @ AIT

Giefinggasse 2 | 1210 Vienna | Austria

Email: helfried.brunner@ait.ac.at / Telephone: 0043 (0) 664 620 78 75

